



02 December 2009

To: **Qualified Bidders**

Re: **CRC Institute Green Training Center**

ADDENDUM NO. 1

Jacksonville, Florida

This addendum forms a part of the Bidding/Permit Documents dated 09 November 2009 and will be incorporated into Contract Documents as applicable. Please acknowledge receipt of this addendum by referencing its number and date in your bid proposal.

ADDITIONS OR MODIFICATION TO DRAWINGS DATED 09 NOVEMBER 2009

Item 1

Floor Finishes: Please see attached revised Finish Schedule SK-01.

Item 2

Reception Desks: The reception desks at Primary Entrance 100 and Secondary Entrance 110 will be systems furniture and provided by owner.

Item 3

Land Lord Suite: Please provide complete pricing for the land lord suite as a separate line item in base bid.

Item 4

Concrete Slab at Entrances: Existing concrete slab at Entry is recessed below existing door threshold. The GC is to remove portion of concrete slab at door and replace with new concrete slab meeting ADA requirements.

Item 5

Fire Dampers: Office 111 is shown to be provided HVAC from the split system, HP1. Please confirm if fire dampers will be required at the wall penetrations for the supply and return; **Response: Please provide fire dampers at Office 111 as well as Closet 112.**

Item 6

Electrical Notes: Disregard note # 1 on sheet E2.2 regarding floor box outlets under desk.

ADDITION OF PRODUCT SPECIFICATIONS DATED 02 FEBRUARY 2009

Item 1

Please see attached "Manufactured Casework" specification section 12300 as part of this addendum.

END OF DOCUMENT