

## Addendum 1

bids@kpmeiring.com

**ADDENDUM 1**  
**November 30, 2009**  
**for**  
**AMCD**  
**St Augustine, FL**

### 1. Exterior/Site

- a. Fire Water System will “loop” around the property. A revised site plan will be posted on <http://www.kpmeiring.com/plans.html> which will describe the water service.
- b. Relocate Lift Station and added gravity sanitary lines to Buildings 100 and 200. No Sanitary to Building 300.
- c. Chain Link Fence 8’ with two 24’ (2 pair of 12’ gates) cantilevered gates with automatic operators with key pads for entry and underground wand detector for exiting.

### 2. Building 100

- a. Rooms 116, 117 and 118 will receive cabinets at tops per the attached Specification. There will be one sink per room and price wall cabinets equal to 50% of the length of the base cabinets.
- b. Room 115 does not have base or wall cabinets. The top indicated will be  $\frac{3}{4}$  A/C plywood supported by large metal triangular wall mounted shelf brackets.
- c. Rooms 116, 117 and 118 to have separate A/C units with ducted returns so not to mix the air in these rooms with the other rooms in the building.
- d. Room 134 to receive humidifier so that humidity can be maintained up to 90%.
- e. All other Mechanical Units in Building 100 to be split systems with ducted return.

### 3. Building 200

- a. Garage Doors (120 MPH Large Missal Impact) with automatic openers
  - i. 14 – 20’ x 10’
  - ii. 3 – 12’ x 14’
  - iii. 1 – 10’ x 10’
- b. Room 210 to have PTAC unit. All other rooms to be unconditioned.

### 4. Building 300

- a. **Garage Doors (120 MPH Large Missal Impact) with automatic openers**
  - i. **2 – 12' x 10'**
  - ii. **1 – Set Dock Bumpers at truck well door.**
- b. **Fire Protection System in this building.**
- c. **Thru Wall A/C unit as required to keep building under 80 degrees**

**5. BID DATE REMAINS: Friday December 11, 2009 @ 2:00 PM**

---

**6519 Carrollton Ave  
Indianapolis, IN 46220  
T: (317) 257 7506  
F: (317) 254 1305**

**1715 Lakeside Ave #5  
St. Augustine, FL 32084  
T: (904) 810 5101  
F: (904) 810 5138**